

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

SPENCER WATER DEPT, WV3304405

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 10/1/2022 and 12/31/2022, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
27, MONITORING, ROUTINE (DBP), MAJOR Failure to Monitor/Report Disinfectant By-Product Precursors (TOC and/or Alkalinity)	10/1/2022 to 12/31/2022

What happened? What is being done? (Describe corrective action)

Samples were sent to the Laboratory Services that are routinely used for monitoring, the Laboratory ran the samples and sent the results to the Spencer Water Department. The Spencer Water Department in turn sent the results to the State Department of Health without realizing that the Laboratory had ran the samples outside of the timeline for which they are required to sample within which resulted in the samples being invalid for reporting purposes. The samples which were sent to the Laboratory in the months after this violation were sampled within the timeline and are within reporting requirements which would put the Spencer Water Department back in compliance with EPA requirements.

For more information, please contact Mark Ray at 304 – 927 – 1497
(Contact name) (Phone number)
Or 116 Court Street, Spencer, W.V. 25276
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **Spencer Water Department**

State Water System ID#: WV3304405

Date Distributed: June 16, 2023